

TEST REPORT

Report No.: [REDACTED]

Rendered to:

INTERSTATE BUILDING MATERIALS, INC.
Pittston, Pennsylvania

PRODUCT TYPE: Double Hung Window (Composite Material)
SERIES/MODEL: 9400 DH

SPECIFICATION: AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
Primary Product Designator	Class R PG50 118 x 1601 (44 x 63) Type H
Design Pressure	± 2400 Pa (50.13 psf)
Air Infiltration	0.73 L/s/m ² (0.14 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A2
Water Penetration Resistance Test Pressure	360 Pa (7.52 psf)

Test Completion Date: 03/21/2012

Reference must be made to Report No. [REDACTED] dated 07/30/12, for complete test specimen description and detailed test results.