



NATIONAL CERTIFIED TESTING LABORATORIES

3110 HILL AVENUE • EVERETT, WASHINGTON 98201 • TELEPHONE (425) 259-6799
FAX (425) 259-4995
www.nctlinc.com

AAMA/WDMA/CSA 101 I.S.2/A440-08 STRUCTURAL TEST REPORT SUMMARY

RENDERED TO:

MIKRON INDUSTRIES
1034 6TH AVENUE NORTH
KENT, WA. 98032

MODEL/TYPE: 1700 SERIES DIRECT SET PICTURE WINDOW

TITLE	SUMMARY OF RESULTS
Primary Product Designator	Class CW - PG55 3045 x 1829 (120 x 72) - Type FW
Air Infiltration/Exfiltration	< 0.01 L/s/m ² (< 0.01 cfm/ft ²) - Infiltration < 0.01 L/s/m ² (< 0.01 cfm/ft ²) - Exfiltration
Water Penetration Resistance	380 Pa (12.00 psf)
Design Pressure	± 2640 Pa (53.0 psf)
Uniform Load Structural Test	± 3960 Pa (82.5 psf)
Forced Entry Resistance	Passed ASTM F 308-07 Passed CMBSO 1-79, CAWM 301

Test Completion Date: 04/03/2012

Reference must be made to NCTL Report Number [redacted] dated 04/16/2012 for complete test sample description and data.

For National Certified Testing Laboratories:

Jeffrey M. Douglas
Laboratory Manager