

TEST REPORT

Report No.: [REDACTED]

Rendered to:

INTERSTATE BUILDING MATERIALS, INC.
Pittston, Pennsylvania

PRODUCT TYPE: Fixed Window (Composite material)
SERIES/MODEL: 1750 DSET PW Fixed

SPECIFICATION: AAMA/WDMA/CSA 101/LS.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
Primary Product Designator	Class CW PG50 3048 x 1828 (120 x 72) Type FW
Design Pressure	± 2400 Pa (50.13 psf)
Air Infiltration	< 0.01 L/s/m ² (< 0.01 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	Fixed
Water Penetration Resistance Test Pressure	440 Pa (12.11 psf)

Test Completion Date: 02/08/2013

Reference must be made to Report No. [REDACTED] dated 02/14/13, for complete test specimen description and detailed test results.