



TEST REPORT

Report No.: C1479.04-901-44

Rendered to:

INTERSTATE BUILDING MATERIALS, INC.
Pittston, Pennsylvania

PRODUCT TYPE: Sliding Door XO

SERIES/MODEL: 4000 Patio Door

SPECIFICATION: AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
Primary Product Designator	Class R PG30 1828 x 2085 (72 x 82) Type SD
Design Pressure	+1440 Pa (30.08 psf)
Air Infiltration	0.36 L/s/m ² (0.07 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	330 Pa (6.90 psi)

Test Completion Date: 09/24/2012

Reference must be made to Report No. C1479.04-901-44, dated 03/15/13, for complete test specimen description and detailed test results.